

VILLAGE OF DOWNERS GROVE
Report for the Village Council Meeting
4/11/2017

SUBJECT:	SUBMITTED BY:
Motion to approve payment to Total Fire & Safety, Inc. for emergency fire alarm system repairs	Kurt Bluder Police Chief

SYNOPSIS

A motion is requested to approve payment in the amount of \$18,875 to Total Fire & Safety, Inc. for emergency fire alarm system repairs. This emergency repair service was performed in 2016, and resulted from a malfunction to the Village Operations Center uninterrupted power supply (UPS). The UPS is owned by the DuPage County Emergency Telephone Systems Board (ETSB).

STRATEGIC PLAN ALIGNMENT

The goals for 2015-2017 include *Exceptional Municipal Services*.

FISCAL IMPACT

This expense was not a budgeted item in the FY17 budget. The payment of \$18,875 is offset by reimbursement from the ETSB in the amount of \$18,875.

RECOMMENDATION

Approval on the April 11, 2017 consent agenda.

BACKGROUND

In August of 2016, the Village Operations Center experienced a power surge resulting from a malfunction of the ETSB owned uninterrupted power supply. The power surge caused damage to the Village owned fire alarm system. Total Fire & Safety, Inc. provided emergency services to repair the system. The ETSB has reimbursed the Village of Downers Grove for the full cost of the repairs.

ATTACHMENTS

Invoice



6808 Hobson Valley Dr. #105 Woodridge, IL 60517

Phone (630) 960-5060 Fax (630) 960-4823

www.totalfireandsafety.com

Invoice Number	11012016
Invoice Date	11/10/2016
Date Due	Upon Receipt
Account	20632
Purchase Order	

INVOICE

Bill To:
 Village of Downers Grove
 801 Burlington Avenue
 Downers Grove, IL 60515

Service Location:
 Downers Grove PD
 Dispatch Center
 825 Burlington
 Downers Grove, IL 60515

Products/Service	Description	Qty	Price	Amount
	Emergency Call - Digital Alarm Receivers not working			
8/15/2016	Both primary and back-up receivers for Digital Alarms not working. Found both receivers took a power surge and blew out. Worked on repair to get alarm working			
8/16/2016	Continued repairs. Removed 1 receiver from rack. Found power supply card damaged. Used AES Radio as charger to a 12V7amp battery. Used battery to power receiver as a temporary fix. Copied program to install in new unit.			
8/17/2016	Installed and programmed new Digital Alarm receiver. Tested all new programming. Removed old unit to send out for repair			
10/11/2016	Removed 2nd damaged receiver in the secondary set-up. Installed the Digital Receiver that was factory repaired. Shut down everything for UPS cut over. Rebooted and Re-initialized.			
11/10/2016	Repaired 2nd receiver from dispatch center that was damaged			
	Labor			\$5,225.00
	Parts/materials			\$13,650.00
			Subtotal	\$18,875.00
			Tax	\$0.00
			Total	\$18,875.00

License Alarm IL : 127.001462 Sprinkler: IL FSC0248

Interest of 1.75% per month (21% annual) will be charged to all invoices past due. All collection and legal fees will be your responsibility. All products remain property of Total Fire & Safety until invoice is paid in full.